



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/07/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO33M	Olr acted	Reset done	23:25:00	23:30:00	
2	OHP	CO35	olr acted	Reset done	00:20:00	00:25:00	
3	OHP	BRC on CO33M	BW tripped found manually doing job	No problem found	00:55:00	01:10:00	
4	OHP	CO7A	ZSS cage got struck	ZSS bypassed in module	23:10:00	23:30:00	informed to A shift ZSS cages not ready may arrange in G shift
5	OHP	CO17(Flap gate 5) to CO23	PB not released properly and jamming is there	Informed to operation and PB released	03:00:00	03:30:00	changed from CO18 to CO23
6	OHP	CR3	Tripped 2 times due to stone struck	Reset done	00:15:00	00:18:00	05.30am to 05.35am
7	OHP	TT2	LT not working found MPCB trip	Made it on	23:10:00	23:20:00	
8	OHP	CO15	MPD trip in olr	Reset done	22:45:00	22:50:00	
9	CHP	SCR 4 ON CC 33	LT NOT WORKING,OT acted	OT released	23:10:00	23:20:00	
10	CHP	CC 34 scr 2	LT NOT WORKING,OT acted	OT released	02:40:00	02:50:00	
11	CHP	CC 17	OLr acted	reset	04:10:00	04:15:00	
12	CHP	CC 114	OLR acted	reset	00:05:00	00:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/07/2025

Shift: C

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC52 TIS	mccb TRIPPED DUE TO OUTGOING CABLE connector melted	new connector replaced	01:10:00	01:30:00	
14	CHP	CC 51A	ZSS acted,belt snapped	informed mech and operation	04:30:00	04:35:00	
15	CHP	CC52	olr tripped and feeding conveyor got stopped 5 times	Reset done	23:35:00	23:40:00	12.10am to 12.15am: 01.25am to 01.30am:05.05am to 05.10am and 05.35am to 05.40am
16	CHP	CC54	olr acted	Reset done	00:25:00	00:30:00	2 times
17	CHP	CC125	olr acted	Reset done	05:35:00	05:40:00	
18	CHP	S1 on CC38	PCRD gear box layering key problem	machine taken tail end cable drum arrested and loop left in drum	05:30:00	06:00:00	
19	WT	CO 3(b)	OLR acted due to jamming	reset	23:40:00	23:45:00	
20	WT	OC 1A	olr acted, due to jamming	reset. informed operation	02:10:00	02:15:00	
21	WT	OT 4	not rotating,drive 1 trips in pgf4 fault	reset	05:15:00	05:20:00	
22	IOSA	new WOBR	LT not working found M2 thruster break MPCB tripped	Made on	23:00:00	23:10:00	