



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: C

| Sl No | Area | Equipment     | Problem                      | Action                      | From                             | To                               | Remarks |
|-------|------|---------------|------------------------------|-----------------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | co-25         | tripped on olr               | RESET DONE                  | 02:00:00<br>22:55:00<br>23:20:00 | 02:10:00<br>23:00:00<br>23:30:00 |         |
| 2     | OHP  | BRC ON CO-30  | BC ZSS NOT IN PLACE          | KEPT IN PLACE               | 01:45:00                         | 02:00:00                         |         |
| 3     | OHP  | BRC ON CO-30  | BC OLR ACTED                 | RESET DONE                  | 04:36:00                         | 04:45:00                         |         |
| 4     | OHP  | BRC ON CO 8A  | ACB TRIPPED                  | RELEASED                    | 04:00:00                         | 04:15:00                         |         |
| 5     | OHP  | CO-26         | OLR ACTED                    | RESET                       | 04:10:00                         | 04:15:00                         |         |
| 6     | OHP  | BRC ON CO-34  | LT NOT WORKING OT ACTED PCRD | RELEASED ... GUIDE ADJUSTED | 23:10:00                         | 23:25:00                         |         |
| 7     | CHP  | CC-47         | FAIL TO START                | CONTROL RECYCLE AND TESTED  | 23:20:00                         | 23:33:00                         |         |
| 8     | CHP  | CC-104 SCR -9 | LT NOT WORKING PCRD OT ACTED | RELEASED                    | 23:30:00                         | 23:45:00                         |         |
| 9     | CHP  | CC-39 S-1     | LT NOT WORKING DRIVE TRIPPED | RESET                       | 03:26:00                         | 03:40:00                         |         |
| 10    | CHP  | CC-51         | TRIPPED ON MPD               | RESET                       | 00:20:00<br>00:50:00             | 00:25:00<br>00:55:00             |         |
| 11    | CHP  | CC-55         | TRIPPED ON OLR               | RESET DONE                  | 00:30:00                         | 00:40:00                         |         |
| 12    | CHP  | CC-58         | TRIPPED ON OLR 3 TIMES       | RESET DONE                  | 00:40:00                         | 01:05:00                         |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem                   | Action     | From     | To       | Remarks   |
|-------|------|-----------|---------------------------|------------|----------|----------|---|
| 13    | IOSA | oc-27a    | MOTOR PROTECTION TRIPPING | RESET DONE | 22:30:00 | 06:00:00 | DECK SHEETS FULL JAM INFORMED OPERATION (NO ELECTRICAL PROBLEM) |