



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	07:30:00	07:40:00	
2	OHP	WOBR ON CO-26	REPORTED LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	08:45:00	09:00:00	
3	OHP	WOBR ON CO-26	REPORTED SLEW NOT WORKING DRIVE TRIP	RESET DONE	09:15:00	09:25:00	
4	OHP	TW-5 CO-17 TO CO-23	TRIPPED ON OLR	RESET DONE	11:00:00	11:15:00	
5	OHP	CO-8	OLR ACTED	RESET DONE	12:00:00	12:10:00	
6	OHP	BRC ON CO-32	REPORTED B/W S NOT RUNNING FENDING FROM NIGHT SHIFT FOUND ZSS SUPPLY LOOSE AND STONE STUCK UP	ZSS WIRES TIGHT AND STONE REMOVED THAN OK	07:25:00	07:50:00	
7	OHP	BRC ON CO-32	REPORTED PUMP NOT RUNNING FOUND PLC UNIT WIRES LOOSE CT LIMIT WIRE ALSO LOOSE	ALL WIRES ARE TIGHT THAN OK	08:30:00	09:30:00	
8	CHP	CC-54	OLR TRIP (10 TIMES)	RESET DONE	10:55:00	13:45:00	
9	CHP	CC-45	OLR TRIP (3TIMES)	RESET DONE	06:30:00 08:30:00 09:25:00	06:40:00 08:35:00 09:30:00	
10	CHP	CC-36 SCR-2	SLEW NOT WORKING DRIVE TRIP	RESET DONE	06:55:00	07:10:00	
11	CHP	CC-36	OLR ACTED	RESET DONE	08:40:00	08:45:00	
12	CHP	CC-125	OLR ACTED	RESET DONE	12:55:00	13:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-112 SCR-8	SLEW NOT WORKING FOUND SLEW PINEON DAMAGED	INFORMED TO MECHANICAL	13:00:00	13:15:00	
14	WT	CP-3	NOT MOVE	DRIVE -3 AUX-RELAY BYPASSED THAN OK	06:33:00	07:30:00	
15	IOSA	OC-23,27, 29 OC-7A, 5A	SHOWING RED FOUND LBDS-2 OM-2 ACB TRIP	MADE ON THAN OK	13:30:00	13:45:00	