



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/12/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 84	OLR ACTED	RESET	17:20:00	17:25:00	
2	OHP	CO 25	OLR ACTED	RESET	18:55:00	19:05:00	
3	OHP	CO 58	OLR ACTED	RESET	19:20:00 20:10:00	19:30:00 20:15:00	
4	OHP	BRC ON CO 34	PCRD O/T ACTED	RESET	18:05:00	18:10:00	
5	OHP	TBS ON CO 21	LT RUNNING AUTOMATICALLY DUE BRAKES LOOSE	INFORMED TO MECH	18:20:00	18:30:00	
6	OHP	CO 14, CO 15 AND TT1	CHUTE SENSOR CONNECTIONS DISTURBED BY INSTRUMENTATION CONTRACT PERSONS	PROPERLY CONNECTED	15:45:00	16:45:00	
7	OHP	CO 58 RED	Y PHASE GOT CUT IN MOTOR PJB	RECONNECTED	21:20:00	21:40:00	
8	OHP	CO 111	OLR ACTED	RESET	21:25:00	21:40:00	
9	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	17:15:00	21:30:00	4 TIMES
10	CHP	CC 117	OLR ACTED	RESET	21:20:00	21:30:00	
11	CHP	CC 53	MPCB TRIP	MADE IT ON	16:45:00	16:55:00	
12	CHP	S1 ON CC 39 LT	DRIVE TRIP	RESET	17:10:00	17:20:00	
13	CHP	CC 44	OLR ACTED	RESET	19:10:00	19:15:00	
14	CHP	R1 ON CC 32	LUFF NOT WORKING DUE TO MATERIAL JAMMING ON B/W AREA AND HEAVY LOAD ON CONVEYOR	INFORMED TO OPRN	19:30:00	19:50:00	