



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/06/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	ISOLATOR AND VACCUM INTERRUPTOR UNIT CABLE ISOLATION IS IN PROGRESS
OC-19A	TUNNEL LIGHTING DEFECTS RECTIFIED AND LIGHT ARRANGED.
OC-21A	LIGHTING DEFECTS RECTIFIED AND RECTIFIED LIGHTS ARRANGED.
OC-37A	PPM DONE ON MOTOR AND FIELD DEVICES. SPARE MOTOR CLEANING AND MEGGERING DONE.