



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/12/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 32	LT not working,OT acted	reset	00:45:00	01:00:00	
2	OHP	CO 77	olr acted	reset	00:50:00	01:00:00	
3	OHP	BRC on Co 8A	b/w 2 not running,stone stucked	informed operation	04:15:00	04:25:00	
4	CHP	CC 38 SCR6	b/c not running,mpd tripped	reset	00:50:00	05:15:00	full jamming,3 times tripped
5	CHP	CC 31 SCR4	slew not working,wrong complaint	informed operation	04:00:00	04:10:00	
6	CHP	CC 32 SCR 5	Lt not working,m6 mpcb tripped	made it on	04:10:00	04:20:00	
7	CHP	CC 105 scr 10	b/c not running,mpd tripped	rset	04:40:00	04:55:00	
8	CHP	CC 104 SCR9	luffing not working,mpcb tripped	made it on	05:05:00	05:20:00	
9	CHP	cc 51	mpd tripped	reset	04:00:00	04:05:00	
10	CHP	cc 55	olr acted	reset	05:00:00	05:05:00	