



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VF 23	M1 mpcb tripped r phase got cut	r phase jointed and mpcb made on	08:00:00	08:15:00	
2	OHP	brc on co 28	Lt not working,heavily track jamming,M1 mpcb tripped	informed operation and m1 made on	07:15:00	07:25:00	
3	OHP	CO 84	olr acted	reset	08:00:00	08:15:00	
4	OHP	wobr on CO 6A	luffing not working,oil level zero	informed operation and mechanical	08:40:00	08:50:00	
5	OHP	CO 26	olr acted	reset	08:50:00	08:59:00	
6	OHP	CO 25	olr acted	reset	13:30:00	13:40:00	
7	OHP	BRC on CO 31	b/c olr acted	reset	09:40:00	09:50:00	
8	OHP	tbs on co20	LBC and luff olr acted	reset	13:00:00	13:20:00	
9	CHP	CC 51	olr acted	reset	08:54:00	09:20:00	2 times
10	CHP	CC 51	mpd tripped 10 times	reset	06:30:00	13:50:00	
11	CHP	CC 52	mpd tripped	reset	12:35:00	12:40:00	
12	CHP	CC 54	olr acted	reset	07:00:00	13:40:00	10 times
13	CHP	CC 117	olr acted 4 times	reset	08:00:00	12:30:00	
14	CHP	Co 26	zss acted	wrong complaint	12:30:00	12:40:00	
15	CHP	CC 33 R1	bc not running motor tripped in olr	reset	07:10:00	07:20:00	
16	CHP	CC 35 SCR3	bc not running,olr acted	reset	08:30:00	08:40:00	
17	CHP	C 33 R1	b/c not running,gearbox oil leakage	informed operation	12:10:00	12:20:00	