



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/07/2025

Area: IOSA

Equipment	Job
OC-21A and 23A	LIGHTING DB CLEANING , TIGHTNESS AND RECTIFICATION DONE.
1-142LC-2	HOUSEKEEPING DONE IN PLC AND MCC ROOMS
OC-23A	ELECTRICAL HOIST RECTIFIED AND CHECKED.
OC-11A	RUNNING AND SPARE MOTORS COVERED WITH BELT PIECE AS RAIN WATER FALLING ON MOTORS DUE TO SHED ROOF SHEETS GOT RUSTED AND DAMAGED.
OC-27A	PPM DONE ON ZONE-2 and 3 FIELD DEVICES .
WOBR (L and T)	ZSS OF MACHINE TO YARD TAKEN IN LINE AND FEEDBACK AND INTERLOCK CHECKED.
OJH-11A and 12A	ELECTRICAL HOIST MOTOR MPCB REPLACEMENT.
OC-19A	DE-WATERING PUMPS CHECKED IN AUTO.