



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/06/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO8	ZSScage struck in reverse and probe damage	Probe replaces and cage placed properly	02:20:00	03:15:00	Return roller not available fallen from conveyor frame is to be fixed by mech dept informed to mech dept 02.20 pm to 03.15