



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/02/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO B/W 2	MPCB TRIP DUE TO CABLE RUB	PROPERLY INSULATED THEN OK	15:50:00	16:20:00	
2	OHP	BRC ON CO 28 CT	DRIVE TRIPPED	RESET	18:00:00	18:10:00	
3	OHP	WBR ON CO 29 SLEW	DRIVE TRIPPED	RESET	19:10:00	19:20:00	
4	OHP	CO 34	OLR ACTED	RESET	20:15:00	20:20:00	
5	CHP	CC 223	DRIVE TRIPPED	RESET	16:30:00	16:40:00	
6	CHP	SCR 3 ON CC 37 B/C	OLR ACTED	RESET	19:40:00	19:50:00	
7	CHP	CC 218	C/S ACTING DUE TO MOISTURE	CLEANED	21:30:00	21:40:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	17:00:00	21:30:00	7 TIMES
9	CHP	CC 51	OLR ACTED	RESET	17:15:00	17:20:00	
10	CHP	CC 113A	OLR ACTED	RESET	15:30:00	15:35:00	
11	CHP	CC 52	CONTROL MCB TRIPPED	MADE IT ON	21:00:00	21:05:00	
12	WT	OT 4	DRIVE 2 TRIPPED ON PGF1	RESET	19:00:00	19:10:00	
13	WT	OT3	DRIVE 1 TRIPPED ON ENCODER FAULT	RESET	20:00:00	20:05:00	