



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/06/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 6A	LT and BC not running	Power in off condition , made on	17:35:00	17:50:00	
2	OHP	TBS on CO 19	LT not working due to boom is not at rec height	Height adjusted , then LT done	18:05:00	18:20:00	
3	OHP	CO 35	OLR acted	reset done	19:00:00 20:25:00	19:05:00 20:30:00	
4	OHP	CR 1	oil flow switch problem	switch cleaned and fixed	20:00:00	20:15:00	
5	OHP	CO 66	BRS bypassed on operation request	bypassed	20:15:00	20:20:00	
6	OHP	CO 35A	BRS kept in circuit	as per opn request	15:40:00	15:45:00	
7	OHP	CO 7	MPR problem	Rectified by G shift	16:00:00	17:00:00	
8	OHP	CO 29	OLR acted	reset done	16:45:00	16:50:00	
9	OHP	CO 14	BRS kept in circuit	operation request	21:30:00	21:35:00	
10	CHP	CC 36 , SCR 1	Slew not working	Found material jamming , informed operation for cleaning	15:55:00	16:25:00	
11	CHP	CC 32 , SCR 5	LT not working	M-2 and M-3 tripped . Reset done	14:05:00	14:25:00	
12	CHP	CC 32 , SCR 5	BC not running reported	TUL chute jamming , informed to operation for cleaning	16:30:00	16:50:00	
13	CHP	CC 131	Tripped on overload ( 4 times)	reset done	15:10:00	16:50:00	
14	CHP	CC 53	Stopped on Zero speed ( 2 times)	Belt offcentering and coal stuck on cage. Informed to mechanical and operation	19:45:00	20:15:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/06/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC 36 , SCR 1	Slew not working	30 degree limit acted ,BC made off . Then slewing done	18:30:00	18:40:00	
16	CHP	CC 25	ZSS cage reversed and stuck	Cage adjusted	21:15:00	22:00:00	
17	IOSA	TBS	LT limit switch acted acted due to jungle	limit switch Bypassed	19:00:00	19:15:00	
18	IOSA	TBS	BC signal missing	LT done	17:45:00	18:05:00	