



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 7A	No drive running	Main breaker and control off condition. made it on	22:30:00	23:00:00	
2	OHP	CO 63	showing red	control in off condition and emergency acted	23:45:00	00:00:00	
3	OHP	CO 2A	Stopped on zero speed	probe wire got cut , joint done	22:40:00	23:00:00	
4	OHP	RSCO 6A	OLR acted	reset done	02:30:00	02:40:00	
5	OHP	CO 13 carriage drive	OLR acted	reset done	02:45:00	03:00:00	
6	OHP	WOBR on CO 25	BC not running	ZSS acted due to stone stuck in cage. Stone removed then ok	00:05:00	00:25:00	
7	OHP	CO 35	BRS not getting reset	reset push button stuck , made free	00:35:00	00:40:00	
8	OHP	BRC on CO 34	CT not working	limit stucked near cabin side , made free	02:40:00	03:00:00	
9	OHP	TBS on co 22	right luff not working	OLR acted , reset done	04:00:00 04:45:00	04:20:00 05:00:00	
10	OHP	BRC on CO 28	PCRD cable overlapped	cable winding done properly with mechanical	04:40:00	05:00:00	
11	OHP	TT1 chute vibrator	not working	material jamming on vibrator . Cleaned	05:30:00	05:45:00	
12	CHP	CC 34 , SCR 2	LT not working due to PCRD overtension	tension released	03:10:00 04:15:00	03:25:00 04:30:00	
13	CHP	CC 38 , SCR 3	BC not running	chute sensor acted due to jamming. Informed operation for cleaning	04:45:00	05:00:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 112 , SCR 8	BC not running	chute sensor acted due to rain. Bypassed in module	05:15:00	05:30:00	
15	CHP	CC 54	Tripped on overload (3 times)	reset done	22:20:00	03:55:00	
16	CHP	VS 3	Tripped on overload (3 times)	reset done	01:30:00	02:00:00	
17	CHP	CC 131	Tripped on overload (2 times)	reset done	00:50:00	01:55:00	
18	CHP	CC 130	TIS not healthy	loose contact in TIS epb , after tightened then TIS healthy	03:30:00	03:40:00	
19	WT	CT	IO rack control supply not there	supply given from different source	22:00:00	23:00:00	
20	WT	OP 5	Not moving	emergency acted , released	03:20:00	03:30:00	