



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/10/2025

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|---------------------------------|----------------------------------|----------------------------------|---------|
| 1 | OHP | WOBR OON CO-6A | B/C OLR ACTED | RESET DONE | 01:30:00 | 01:40:00 | |
| 2 | OHP | CO-10A | OLR ACTED (3TIMES) DUE TO MATERIAL JAMMING | RESET DONE | 01:35:00 03:50:00 23:35:00 | 01:45:00 04:00:00 23:45:00 | |
| 3 | OHP | CO-34 | OLR ACTED (2TIMES) DUE TO JAMMING | RESET DONE | 01:10:00 | 01:30:00 | |
| 4 | OHP | WOBR ON CO-29 | SLEW NOT WORKING FOUND OLR ACTED | RESET DONE | 02:35:00 | 02:45:00 | |
| 5 | OHP | CO-43A | REPORTED NOT HEALTHY C/S ACTED DUE TO CHUTE JAMMING | AFTER CLEAN MATERIAL RESET DONE | 04:45:00 | 05:00:00 | |
| 6 | CHP | CC-37 SCR-7 | SLEW NOT WORKING FOUND SPIDER BREAK FAIL ALARM ACTED | RESET DONE | 02:20:00 | 02:40:00 | |
| 7 | CHP | CC-38 SCR-6 | SLEW NOT WORKING CHECKED AND FOUND MATERIAL JAMMING | INFORMED TO OPERATION | 03:35:00 | 03:45:00 | |