



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/06/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT 1	Flap gate MPCB tripped	made on	17:00:00	17:15:00	
2	OHP	CO 87	MPR tripping in unbalance current	Motor termination and contactor checked , current checked . Found okay and given clearance	15:20:00	16:00:00	
3	OHP	CO 9A	BRS fuse blown in CJB	Checked and fuse replaced	18:00:00	18:20:00	
4	OHP	CO 7A	Stopping on ZSS	Probe prblm , probe replaced	16:20:00	16:40:00	
5	OHP	CO 26 WOB	Slewing not working	Drive tripped , reset done	18:25:00	18:45:00	
6	OHP	BF 8A	ZSS probe and module problem	Changed module and probe	21:20:00	21:45:00	
7	OHP	SB 2A	Bunker level zero	Bypass removed	19:30:00	19:45:00	
8	CHP	CC 51	Pull chord acted due to mechanical work	Reset	15:40:00	16:00:00	
9	CHP	CC 53	Pull chord acted due to operation work	reset done	15:30:00	15:35:00	
10	CHP	CC 131	Tripped on overload	reset done	15:30:00 17:40:00	15:35:00 17:45:00	
11	CHP	CC 54	Tripped on overload	reset done	19:30:00	19:35:00	
12	CHP	CC 132	BRS bypassed	Operation request	17:30:00	17:35:00	
13	CHP	CC 114	BRS bypassed	Operation request	19:30:00	19:35:00	
14	CHP	CC 48	Chute sensor not healthy	Module problem. replaced	16:20:00	17:20:00	
15	CHP	CC 223	Drive tripped	reset done	21:00:00	21:15:00	
16	CHP	CC 33 , SCR 4	Slew speed to be adjusted as per operation request	Slew speed reduced	18:45:00	19:00:00	