



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/09/2025

Incharge(s): Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 16	MPR tripped	reset done	23:15:00	23:25:00	
2	OHP	CO 14	ZSS acting	ZSS module speed decrease	01:30:00	01:50:00	
3	OHP	BRC on CO 32	LT not taking place	selector in local mode, changed to remote	02:30:00	02:50:00	
4	OHP	TBS on CO 21	Chute sensor acted , malfunctioning	checked, working well	01:10:00	01:30:00	
5	OHP	CO 26	OLR acted	reset done	03:45:00	03:55:00	
6	OHP	CO 29	OLR done (2 times)	reset done	03:55:00	05:10:00	
7	CHP	CC 112	Tripped on overload	reset done	22:30:00	22:45:00	
8	CHP	CC 36 , SCR 1	Slew not working	slew area jamming , after cleaning 30 degree left and right not healthy. So bypassed and slewing done	23:30:00	00:00:00	
9	CHP	CC 112 , SCR 8	Slew not working due to 30 degree limit acted OHP side	Bypassed and slewing done	02:45:00	03:00:00	
10	CHP	CC 112	ZSS acting due to coal on belt	Informed to opn	05:00:00	05:20:00	
11	CHP	CC 125	Tripped on overload	reset done	03:40:00	03:50:00	
12	CHP	CC 23	Chute sensor acted	sensor cleaned , okay	22:30:00	22:40:00	
13	CHP	CC 28	Chute sensor acted	sensor cleaned , okay	23:37:00	23:45:00	
14	CHP	CC 51	MPD tripped on overload (9 times)	reset done	01:05:00	05:30:00	
15	CHP	CC 54	Tripped on overload	reset done	01:50:00	02:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/09/2025

Incharge(s): Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 51 TIS	TIS feedback not coming bcz of mechanical problem	temporary bypassed , again after mechanical	03:25:00	04:00:00	