



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---|------------------------------|----------|----------|------------------|
| 1 | OHP | VF1A | motor 1 mpcb tripped | made on | 01:15:00 | 01:20:00 | |
| 2 | OHP | TT2 | IT not taking place, | power recycle done | 00:15:00 | 00:30:00 | |
| 3 | OHP | CO 26 | OLr acted | reset | 23:15:00 | 23:25:00 | 4times |
| 4 | OHP | CO 21 | ZSS acted ,caged stucked | cage replaced | 22:20:00 | 22:40:00 | |
| 5 | OHP | BRC on CO 30 | BC olr acted | reset | 03:20:00 | 03:40:00 | |
| 6 | CHP | CC 38 SCR 6 | LT not working,drive trips | drive reset | 03:50:00 | 04:00:00 | fault codef30003 |
| 7 | CHP | CC 201 and 203 | mpd tripped | reset | 04:10:00 | 04:25:00 | |
| 8 | CHP | CC 38 SCR 6 | bc not running,mpd tripped | reset | 05:10:00 | 05:20:00 | |
| 9 | CHP | CC 202 | fail to start,drive ol | reset | 05:40:00 | 05:50:00 | |
| 10 | WT | OP3 | not moving,d1 OLR acted,5A1 contactor stucked | olr reset,contactor released | 23:50:00 | 00:10:00 | |
| 11 | WT | cp2 | not moving,emergency acted | released | 05:00:00 | 05:15:00 | |
| 12 | WT | OT 4 | initial not coming | sensor adjusted | 03:00:00 | 03:15:00 | |