



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|-----------------------------------|----------|----------|----------|
| 1 | OHP | VF 23 | M1 mpcb tripped r phase got cut | r phase jointed and mpcb made on | 08:00:00 | 08:15:00 | |
| 2 | OHP | brc on co 28 | Lt not working,heavily track jamming,M1 mpcb tripped | informed operation and m1 made on | 07:15:00 | 07:25:00 | |
| 3 | OHP | CO 84 | olr acted | reset | 08:00:00 | 08:15:00 | |
| 4 | OHP | wobr on CO 6A | luffing not working,oil level zero | informed operation and mechanical | 08:40:00 | 08:50:00 | |
| 5 | OHP | CO 26 | olr acted | reset | 08:50:00 | 08:59:00 | |
| 6 | OHP | CO 25 | olr acted | reset | 13:30:00 | 13:40:00 | |
| 7 | OHP | BRC on CO 31 | b/c olr acted | reset | 09:40:00 | 09:50:00 | |
| 8 | OHP | tbs on co20 | LBC and luff olr acted | reset | 13:00:00 | 13:20:00 | |
| 9 | CHP | CC 51 | olr acted | reset | 08:54:00 | 09:20:00 | 2 times |
| 10 | CHP | CC 51 | mpd tripped 10 times | reset | 06:30:00 | 13:50:00 | |
| 11 | CHP | CC 52 | mpd tripped | reset | 12:35:00 | 12:40:00 | |
| 12 | CHP | CC 54 | olr acted | reset | 07:00:00 | 13:40:00 | 10 times |
| 13 | CHP | CC 117 | olr acted 4 times | reset | 08:00:00 | 12:30:00 | |
| 14 | CHP | Co 26 | zss acted | wrong complaint | 12:30:00 | 12:40:00 | |
| 15 | CHP | CC 33 R1 | bc not running motor tripped in olr | reset | 07:10:00 | 07:20:00 | |
| 16 | CHP | CC 35 SCR3 | bc not running,olr acted | reset | 08:30:00 | 08:40:00 | |
| 17 | CHP | C 33 R1 | b/c not running,gearbox oil leakage | informed operation | 12:10:00 | 12:20:00 | |