



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 1A	OLr acted	reset	09:55:00	09:59:00	
2	OHP	co 26	olr acted	reset	10:15:00	10:20:00	
3	OHP	co 28	conveyor stop in ZSS fault	check found all ok	10:35:00	10:50:00	
4	OHP	RSCO1A	zss acted ,due to mechanical coupling problem	informed mechanical	11:00:00	11:15:00	
5	OHP	WOBR on CO 26	b/c not running,jamming	informed operation	11:35:00	11:55:00	
6	OHP	BRC on Co28	BW 2 not running,zss problem,110 high cable got cut	bypass ZSS immediately and given clearance,than cable jointed and ZSS kept in ckt	12:30:00	12:45:00	
7	CHP	cc 107	conveyor not healthy,olr acted	reset	10:25:00	10:30:00	
8	CHP	cc 34 scr1	LT not working,drive tripped due to jamming	informed operation	10:55:00	11:05:00	
9	WT	OC 1A	zss acted ,checked nut loose connection	tightened	08:20:00	08:35:00	