



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/07/2025

Area: WT

Equipment	Job
OP 9	R F cable replaced at Bridge side Antenna
OP 9	24 V SMPS replaced in side pusher and OT 5 Bridge for Modem power supply
Others	coupling fixed to spare pusher motor (45KW)
OP 3,8 and 9	after rake maintenance done
CP 2 and 3	after rake maintenance done