



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 15/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 21	L/LUFF NOT TAKING PLACE OLR ACTED	RESET	22:40:00	22:50:00	
2	OHP	CO 35	OLR ACTED	RESET	02:20:00	02:30:00	
3	OHP	BRC ON CO 31	B/W 2 CONTROL MCB TRIP	MADE ON	04:00:00	04:20:00	
4	OHP	CO 58	OLR ACTED	RESET	04:20:00	04:30:00	
5	OHP	CO 14B	NOT RUNNING IN HEALTHY CHECKED F/G SELECTOR SWITCH PROBLEM	SELECTOR SWITCH KEPT IN CO20 SIDE THAN OK	03:00:00	03:30:00	
6	OHP	CC 132	OLR ACTED	RESET	23:05:00	23:15:00	
7	CHP	CC 54	OLR ACTED (3TIMES)	RESET	23:20:00	00:00:00	
8	CHP	CC 105 SCR 10	pending job from B shift, B/C not running, o/p TB no TBQ 1 4U and 2U fuse blown	fuse replaced on 1st TB, temporary fuse wire kept for 2nd TB, trial run taken for both stacking and reclaiming mode	22:00:00	22:20:00	
9	CHP	CC 131	OLR ACTED	RESET	23:40:00	23:50:00	
10	CHP	CC 125	olr acted	reset	02:08:00	02:15:00	
11	CHP	CC 131	HEALTHY NOT RUNNING CHECKED TT BUNKER POSTION INDICATION MISSING	IN FORMED TO OPERATION	23:55:00	00:15:00	
12	CHP	CC 51	STOPPING ON ZS DUE TO BELT SNAP	IN FORMED TO OPERATION	01:40:00	01:50:00	
13	WT	CO 3(B)	OLR ACTED	RESET	01:10:00	01:20:00	
14	IOSA	OC 11A	STOPPING ON ZS CHECKED ZS PROBE WIRE CUT	JOINT DONE THAN OK	02:55:00	03:30:00	