



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC CO-28	CT NOT WORKING ... LIMIT DAMAGED	CHANGED	15:30:00	16:30:00	
2	OHP	CO-6A WBR	BC NOT WORKING ... BSS ACTED DUE TO OFF CENTERING	ADJUSTED BY MECH	17:15:00	18:00:00	
3	OHP	WBR ON CO-25	SLEW NOT WORKING	DRIVE TRIP ... RESET	18:30:00	18:45:00	
4	OHP	CO-30A	ZSS PROB DAMAGED	BYPASSED IN CJB AS PER OPERATION REQUEST	21:00:00	21:10:00	PROB TO BE CHANGED AT 10.00 PM
5	OHP	VF-17	MOTOR SHAFT DAMAGED	CHANGING IN PROCESS	20:40:00	22:00:00	WORK GOING ON
6	CHP	CC-31 SCR-4	LUFF NOT WORKING... DOWN LIMIT ACTED	RELEASED	14:45:00	15:10:00	
7	CHP	CC-38 SCR-6	LT NOT WORKING	TRACK JAMMING .. INFORMED OPERATION	15:20:00	15:30:00	
8	CHP	CC-38 SCR-6	LT NOT WORKING	DRIVE TRIPPED ... RESET	17:28:00	17:32:00	
9	CHP	CC-54	TRIPPED 4 TIMES	RESET DONE	17:57:00	20:00:00	
10	CHP	ccc-222	NOT RUNNING	JAMMING INFORMED OPERATION FOR CLEANING	21:20:00	21:30:00	
11	CHP	CC-34 SCR-2	BC ZSS PROB PROBLEM	BYPASSED ...	20:50:00	21:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	AF-3	DRIVE TRIPPED	RESET DONE	14:30:00	14:45:00	
13	WT	AF-4	DRIVE FAILED	CHANGED	18:15:00	19:25:00	
14	WT	SCO-1A CD	TRIPPED ON OLR	RESET DONE	19:40:00	19:45:00	
15	WT	OT-1	D1 TRIPPED ON PFG1 FAULT	RESET DONE	21:25:00	21:30:00	
16	IOSA	BRC ON OC-16A	YARD ZSS CAGE STUCK	MADE FREE	18:30:00	18:40:00	
17	IOSA	OC-25A	TRIPPED ON OLR	RESET DONE	17:00:00	17:15:00	