



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/01/2026

Area: OHP

Equipment	Job
cr-1,2,3	ht fuse healthy contact is taken to io rack as "panel healthy" bit and kept in circuit.
wobr-1 on repair bay	testing job, dressing and old cables removal is under progress.
CO-78,85,87	MOTOR AND PANEL SIDE ppm is done