



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/02/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 131	OLR ACTED	RESET	03:40:00	03:45:00	
2	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	22:45:00	05:00:00	10 TIMES
3	CHP	CC 223	P/C WIRE LOOSE IN PANEL	TIGHTENED	05:15:00	05:25:00	
4	CHP	CC 32	OLR ACTED	RESET	22:05:00	22:10:00	
5	WT	AF3	DRIVE TRIPPED	RESET	23:15:00	23:20:00	