



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	TRIPPED	RESET	07:45:00	07:55:00	
2	OHP	BRC -30	BC OLR ACTED	RESET	12:00:00	12:15:00	
3	CHP	CC-51	TRIPPED ON MPD 3 TIMES	RESET DONE	07:05:00	09:50:00	
4	CHP	CC-54	OLR ACTED 6 TIMES	RESET DONE	08:45:00	09:10:00	
5	CHP	CC-38 SCR-6	BC ZSS CAGE STUCK	REPLACED	09:20:00	09:40:00	
6	CHP	CC-40 SCR-2	LUFF NOT WORKING	FILTER CLOGGED BYPASS WIER LOOSE ... TIGHTENED	11:50:00	12:00:00	
7	CHP	CC-104 SCR-9	BC ZSS PROB PROBLEM	REPLACED	10:30:00	10:45:00	
8	CHP	CC-28	TRIPPED ON OLR	RESET	09:00:00 10:00:00	09:10:00 10:05:00	
9	IOSA	OC-27A	OLR ACTED DUE JO DECK SHEET JAMMING	RESET DONE	08:00:00	08:40:00	
10	IOSA	BRC	CT DRIVE TRIPPED	RESET	10:00:00	10:10:00	