



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/01/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BPC 1 ZSS	PROBE TO TARGET DISTANCE IS MORE	ADJUSTED THEN OK	16:40:00	16:50:00	
2	OHP	CO 111, 112, 113 RED	IN LC6 I/O RACK NODE 16 RACK FAULT	POWER RECYCLED THEN OK	17:40:00	18:10:00	
3	OHP	CO 26	OLR ACTED	RESET	15:30:00 17:20:00 19:30:00	15:35:00 17:30:00 19:40:00	
4	CHP	R1 ON CC 33 LUFF	OLR ACTED	RESET	17:25:00	17:35:00	
5	CHP	CC 219 ZSS	ZSS TIMER INCREASED FROM 1 SEC TO 6 SEC	THEN OK	17:45:00	18:00:00	
6	CHP	CC 108	OLR ACTED	RESET	20:35:00	20:40:00	
7	CHP	CC 131	OLR ACTED	RESET	19:05:00 21:15:00	19:10:00 21:20:00	
8	CHP	CCC 51 A ZSS	CAGE STUCK	MADE IT FREE THEN OK	20:20:00	20:35:00	
9	CHP	CC 19	OLR ACTED	RESET	16:45:00	16:50:00	
10	CHP	CC 29	OLR ACTED	RESET	14:20:00	14:25:00	
11	WT	CP1 NOT MOVING	TOP PHASE CLAMP NOT CONTACTING PROPERLY FROM COL 16 TO COL 24	AFTER THAT LOCATION REMAINING OK	15:35:00	15:55:00	TO BE CHECKED