



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-7A	Reported LBC and LT not running	Checked and found chute jamming for LBC. Boom lowered and cleaned and tested okay. LT brake MPCB tripping. MPCB bypassed and LT tested okay	06:45:00	07:15:00	
2	OHP	BRC on CO-28	Reported CT not taking place	Checked and found CT wheel derailed. Informed to operation	07:15:00	07:30:00	
3	OHP	TBS on CO-21	PCRD guide problem	Adjustment done along with mechanical.	07:30:00	08:00:00	
4	OHP	CO-35	Reported tripped	OLR acted. Reset done	07:35:00	07:45:00	
5	OHP	VS-2	Reported tripped.	OLR acted. Reset done	07:25:00	07:30:00	
6	OHP	BRC on CO-32	B/C stopping	OLR acted due to return side jamming of the belt. (3times)	12:30:00	12:45:00	Informed to operation
7	OHP	BRC on CO-32	Reported B/C stopping	Due to chute sensor problem. Bypassed due to operation demand	09:15:00	09:30:00	Informed to operation and instrumentation
8	OHP	BRC on CO-30	Reported LT not taking place	Checked and found CRMP side M4 motor brake not releasing even though electrical drum picking up. Mechanical adjustment done and tested okay	10:20:00	10:40:00	
9	OHP	BRC on CO-33M	Reported LT not taking place.	M6 tripped due to track jamming. Reset done	10:20:00	10:50:00	Informed to operation to clear track jamming



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC-113A	Reported tripped	OLR acted(4 times) due to over material on belt	08:10:00	08:20:00	tripped at 8.10 9.10,10.30,1.30
11	CHP	CC-51	Reported feeding conveyor stopped	MPD tripped(4 times)	11:15:00	11:20:00	tripped at 11.15,11.45,12.15,1.30
12	CHP	CC-52	Reported ZSS cage struck up	ZSS cage replaced and tested okay	06:45:00	07:00:00	
13	CHP	CC-117	Reported tripped	OLR acted.Reset done	07:30:00	07:50:00	
14	CHP	CC-18	Stopping on ZSS	Cage stuck up with material.Made free and tested okay	08:20:00	08:40:00	
15	CHP	TT on CC-29	Reported LT not moving	Checked and found one phase not coming.Isolator failed. Made direct and given clearance	08:10:00	08:30:00	
16	CHP	CC-203 on CO-28	Position indication not coming	Bypassed at JB and given clearance	08:30:00	08:40:00	
17	CHP	CC-32 R-1	Reported B/C not running	Checked and found feed table ZSS cage stuck up with material.Made free and tested okay	08:10:00	08:20:00	
18	CHP	CC-36 SCR-1	Reported slew not working	Slew limit acted.Released	08:25:00	08:45:00	
19	CHP	CC-36 SCR-1	Reported B/C not running	Checked and found GVM side B/C signal not coming. Bypassed at I/O rack and tested okay	08:40:00	08:50:00	
20	CHP	CC-37 SCR-7	Reported LT not taking place	PCRD overtension acted.Released and tested okay	08:30:00	08:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
21	CHP	CC-38 SCR-6	Reported B/C not running	Chute Sensor acted.Jamming found.	10:05:00	10:20:00	Informed to Operation
22	CHP	CC-36 SCR-1	Reported slew not taking place	Wrong complaint.	10:50:00	11:10:00	
23	CHP	CC-38 SCR-6	Reported LT not taking place	Drive tripped.Reset done and tested okay	12:10:00	12:20:00	
24	CHP	CC-39 s-1	Reported LT not taking place	Drive tripped.Reset done	13:15:00	13:30:00	
25	CHP	All coal pushers	Reported no communication	Modem power recycled and tested okay	10:00:00	10:15:00	
26	WT	OT-4	Reported not running	Drive-2 tripped on PGEF fault.Reset done	07:00:00 12:00:00	07:10:00 12:10:00	
27	WT	ALL coal pushers	not moving	Modem card failed in LC-10A. Card changed and tested okay	12:20:00	13:00:00	