



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 08/09/2025

Area: OHP

Equipment	Job
jh o-15 hoist	panel incoming cable re joint done and hoist motor cable insulation is damaged at few places. taping is done and tested.
co-59,62,68,rco-1a,rco-2a	motor and panel side ppm is done