



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	tripped on olr	reset done.	07:20:00	07:30:00	
2	OHP	co 26	tripped on olr	reset done	09:00:00	09:10:00	
3	OHP	TT 2 ON BYPASS 1	SIGNAL missing due to spillage material 2times	cable removed from material and termination tighten,. then ok	11:25:00 12:30:00	11:40:00 12:45:00	
4	OHP	wobr on co 6a	slew is not taking place/slew brake not released	temporary bypassed then given clearance	10:30:00	11:30:00	
5	CHP	cc 201,203	tripped on olr	reset done.	06:45:00	06:55:00	
6	CHP	scr 1 on cc34	leffing not taking place/limit acted.	limit reset done	07:25:00	07:35:00	
7	CHP	scr 5 on cc32	bc not running/dmpr tripped one phase loose at panel tb	termination tighten.and reset.	07:57:00	08:05:00	
8	CHP	scr 6 oncc 39	bc not running/mpd tripped on olr due jamming	reset done	11:03:00	11:50:00	
9	CHP	r1 on cc 33	bc not running/interloc zss porobe got damaged	probe and cage repalced. then ok	11:30:00	11:50:00	
10	CHP	cc 114,117 ,	tripped on olr	reset done	08:20:00 08:45:00	08:25:00 08:50:00	
11	CHP	cc 51	mpd acted/feeding conv. stopped.	reset done 2times	08:15:00 12:30:00	08:20:00 12:35:00	
12	CHP	s1 on cc38	lt not taking place/drive tripped on olr	reset done	12:37:00	12:50:00	
13	WT	ot 1	drive one tripped on pgf fault	reset done	06:20:00	06:25:00	
14	WT	cc 3	tripped on mpcb	made on	07:40:00	07:50:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	IOSA	brc on oc 15 a	It not not taking place/m4 brake tripped	reset done	12:15:00	12:25:00	