



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/08/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-26	olr acted	reset	17:45:00	17:55:00	
2	OHP	WOBR ON CO 25	SLEW NOT WORKING OLR ACTED	RESET	20:00:00	20:30:00	
3	OHP	TBS ON CO-23	R/B NOT RUNNING CONTROL MCB OFF	CONTROL MCB MADE ON	17:20:00	17:35:00	
4	OHP	WOBR ON CO-29	B/C STOPPING ON ZS CHECKED ZSS PROBE DAMAGED	ZSS PROBE REPLACED THAN OK	21:00:00	21:40:00	
5	CHP	CC-27	OLR ACTED	RESET	21:00:00	21:10:00	
6	CHP	CC-51	OLR ACTED(2TIMES)	RESET	19:30:00	19:40:00	
7	CHP	CC-54	OLR ACTED	RESET	17:00:00	17:10:00	
8	CHP	CC-51	B/S ACTED	RESET	21:00:00	21:10:00	
9	CHP	CC-132	PULL CHORD ACTED	RESET	19:50:00	20:00:00	
10	CHP	CC-47	NOT HEALTHY E/STOP STUCK UP	RELESED	18:00:00	18:10:00	
11	CHP	CC-104 SCR-9	LT NOT TAKING PLACE	WRONG COMPLAINT	19:40:00	19:50:00	
12	CHP	CC-39 S1	LT REV NOT TAKING PLACE CHECK END LIMIT ACTED	AGAIN KEPT IN CKT	20:45:00	21:00:00	
13	CHP	CC-31 R-1	BC NOT RUNNING	COAL JAMMING STOPPING IN ZSS ... INFORMED TO OPERATION	21:20:00	21:30:00	
14	CHP	CC-32 SCR-5	BC NOT RUNNING	CHUT SENSER ACTING DUE TO RAIN ... BYPASSED	21:55:00	22:05:00	TO BE KEPT IN CKT



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/08/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	OP-3	NOT MOVE D-1 OLR TRIP	RESET	21:20:00	21:30:00	
16	WT	SCO-1A(C/D)	OLR ACTED(2TIMES)	RESET	19:30:00	20:15:00	DUE TO TRACK JAMMING
17	WT	CP-4	NOT MOVE MIDDLE COLLECTOR DAMAGED	C AND U CLAMP ROD REPLACED THAN OK	21:10:00	21:55:00	