



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-8	Reported tripped	OLR acted.Reset done(3 times)	22:20:00	03:40:00	
2	OHP	TBS on CO-22	Reported operations not taking place	Control off.made on and tested okay	02:45:00	03:00:00	
3	OHP	CO-26	Reported tripped	OLR acted.Reset done	05:55:00	06:00:00	
4	CHP	CC-54	Reported tripped	OLR acted.Reset done(7 times)	23:30:00	03:00:00	
5	CHP	Cc-51	Reported tripped	MPD acted.Reset done(5times)	00:00:00	02:20:00	
6	CHP	CC-131	Reported tripped	OLR acted.Reset done(2 times)	23:30:00	03:25:00	
7	CHP	CC-33 SCR-5	HT cable flashover at joint pending from B shift	Cable meggered, joint made by dnw,2 HT fuses replaced at I/O and operations tested okay	22:00:00	02:00:00	
8	CHP	Cc-38 SCR-6	Reported LT not taking place	M-2 tripped.Reset done and tested okay	01:18:00	01:29:00	
9	CHP	CC 105 SCR-10	B/C not running	Fluid oil leakage.	01:15:00	01:30:00	Informed to mechanical
10	CHP	CC 34 SCR-1	Luffing not taking place	wrong complaint	02:51:00	03:02:00	
11	CHP	Cc-32 R-1	Luffing not working	mechanical problem	04:20:00	04:32:00	Informed to mechanical
12	WT	OP-3	Reported no movement	Pads fallen at column 31-32.Pad,jumper,c and u clamps replaced	01:30:00	02:30:00	Not a running complaint
13	WT	OC-1A	Reported tripped	OLR acted.Reset done(3 times).	04:50:00	05:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	IOSA	BRC	Reported not starting	Checked and yard ZSS cage stuck up with stone. Removed and tested okay	01:40:00	01:50:00	