



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/07/2025

Area: WT

Equipment	Job
OP7	NOT MOVING, MIDDLE and BOTTOM C-CLAMP FIXING MAST PLATES TOUCHING TO TROLLEY LINE INSULATOR SETS AT COLNO-13 , MIDDLE AND BOTTOM INSULATOR SETS ADJUSTED THEN OK
OP4	PPM DONE.