



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|--------------------------------------|----------|----------|---------------|
| 1 | OHP | Co 49 | not healthy,BRS acted,fuse blown in control jb | fuse replaced | 00:30:00 | 01:00:00 | |
| 2 | OHP | BRC on CO 33M | Lt problem,OT acted | OT released,LOOP given drum arrested | 02:30:00 | 02:45:00 | guide problem |
| 3 | OHP | CO 35 | OLr acted | reset | 04:20:00 | 04:25:00 | |
| 4 | OHP | BRC on CO 32 | b/c olr acted due to jamming | reset | 02:30:00 | 02:45:00 | |
| 5 | CHP | CC 39 | olr acted | reset | 01:36:00 | 01:42:00 | |
| 6 | CHP | CC 33 | olr acted | reset | 02:50:00 | 02:55:00 | |
| 7 | CHP | CC 33 scr5 | cjd of TUL acted,jamming is there | tul cjd ok | 03:15:00 | 03:25:00 | |
| 8 | CHP | CC 33 SCR5 | Lt not working,wrong complaint | all found ok | 03:25:00 | 03:35:00 | |
| 9 | CHP | CC 38 SCR 6 | slew not working, jamming | informed operation than healthy | 04:40:00 | 04:51:00 | |
| 10 | CHP | CC 32 R1 | BC not working,zss cage stucked by stone | cage made free | 05:18:00 | 05:28:00 | |
| 11 | CHP | CC 112 SCR 8 | luffing not working,oil level low | informed mechanical | 05:20:00 | 05:30:00 | |
| 12 | CHP | CC 23 | ZSS acted, stone stucked in cage | stone removed | 01:00:00 | 01:10:00 | |
| 13 | CHP | CC 109 | pcs acted | reset | 00:05:00 | 00:15:00 | |
| 14 | CHP | CC 29 | cjd acted due to jamming | reset | 00:10:00 | 00:20:00 | |
| 15 | CHP | CC 29 TT | flap gate tripped | reset | 01:05:00 | 01:15:00 | |
| 16 | CHP | CC 45 | olr acted | reset | 05:40:00 | 05:45:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---|--------|----------|----------|---------|
| 17 | CHP | CC 51 | mpd tripped on overload stop feeding conveyor | reset | 23:00:00 | 03:00:00 | |
| 18 | WT | CO 3(B) | olr acted | reset | 04:00:00 | 04:05:00 | 3 times |