



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/08/2025

Area: IOSA

Equipment	Job
LC-2 PLC	MEDIA CONVERTER KEPT IN CPU PANEL AND ETHERNET CABLE CONNECTED TO 3.0.0.X NETWORK.
INSPECTION	INSPECTION DONE ON FIELD DEVICES OF OC-19A,2A,23A,25A, and 27A CONVEYORS
WOBR(L and T)	CHECKED THRUSTER BRAKES AND FILLED OIL.
MISC	FOR DE-WATERING PURPOSE PUMP SHIFTED TO OM-1 FROM OM-4
RUNNING INSPECTION	RI DONE ON OC-7B,9A,11A,13A AND TBS RIGHT BOOM CONVEYOR MOTOR
TRANSFER CAR	PPM DONE ON MOTOR AND FIELD DEVICES