



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/12/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-1A	Reported tripped	OLR acted.Reset done	20:30:00	20:35:00	
2	OHP	BRC on CO-8A	Reported CT not taking place	Fuse burnt.Limit cable checked and insulated properly at a joint and tested okay	17:50:00	18:30:00	
3	OHP	BRC on CO-8A	Reported Ct not taking place	Checked and found JB-1 TO JB-2 core problem.cores changed and tested okay	18:55:00	19:45:00	
4	CHP	CC-51	MPD tripped	Feeding conveyor stopped.Reset done(8 times)	15:10:00	20:30:00	
5	CHP	CC-51	Reported tripped	OLR acted.Reset done	20:10:00	20:15:00	
6	CHP	CC-37 SCR-7	Reported no power	Checked and found HT fuse burnt at I/O panel.Cable meggered and found okay.Fuse replaced and charged and operations tested okay	17:00:00	18:05:00	
7	WT	OT-1	Reported tripped	D1 tripped.Reset done	16:20:00	16:30:00	
8	IOSA	BRC	Reported CT not taking place	Drive tripped(over current fault) due to overload.Reset done	19:10:00	19:20:00	