



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/11/2025

Incharge(s): Lal Singh, Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	C0-32 BRC	BW-1 NOT RUNNING	STONE STUCK ... REMOVED	01:45:00	02:00:00	
2	OHP	CO-30 BRC	YARD ZSS INDICATION MISSING	CAGE STUCK ... RELEASED	02:30:00	02:45:00	
3	OHP	TT-3	SPARK OBSERVED DURING LT IN PCRD CABLE	TAPPING DONE AND TESTED	02:50:00	03:10:00	
4	OHP	CO-26 WBR	LT NOT MOVING	PCRD CONTROL MCB PROBLEM AND OT ACTING ... MCB BYPASSED	04:05:00	04:50:00	INFORMED A SHIFT TO CHANGE MCB
5	CHP	cc-203	TRIPPED ON OLR	RESET DONE	22:40:00	22:50:00	
6	CHP	CC-105 SCR-10	LT NOT WORKING	PCRD OT ... RELEASED AND LOOP ADJUSTED	00:00:00	00:25:00	
7	CHP	CC-39 SCR-2	LT NOT WORKING	PCRD OT ACTED .. RELEASED	03:00:00	03:25:00	
8	CHP	CC-125	TRIPPED ON OLR	RESET DONE	04:55:00	05:00:00	
9	CHP	CC-54	TRIPPED ON OLR	RESET DONE	02:15:00 03:50:00	02:20:00 03:55:00	
10	CHP	CC-29	TRIPPED ON OLR 3 TIMES	RESET DONE	05:00:00	05:40:00	
11	WT	CC-2 CD	NOT MOVING	START PB LOOSES ... FIXED PROPERLY	02:10:00	02:20:00	