



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 21/02/2026

Area: OHP

Equipment	Job
tt-3, tt-4 pcrd cable	pcrd cable inspection is done, tt-3 cable insulation damaged at one place, provided proper insulation.
JH o-2 and JH o-3 gallery	ldb's maintenance is done.
co-50,51 belt carriage, wf-2,3,4,5 ; co-53,56,57	motor and panel side ppm is done.
co-31a,32a,33a chute vibrators	ppm is done
HT motor shed	spare motors details are recorded.
co-61,64 belt and carriage	motor side ppm is done.
locp-2 crusher auxiliaries	solenoid plugs cleaning was done and replaced worn out ones.
co-5	motor and panel side ppm is done.
Crusher-2	Ht fuse replaced in cr-2 panel and 2 spares kept at spare panel in HVMCC.
IO-7	HT io panel maintenance is done.
tbs-3 on co-20	Right Boom mccb is replaced, trail run is taken. RBC gearbox sound observed, mechanical is changing gearbox, trail to be taken after replacement is done, vibrations and currents to be recorded. Spare MCCB module for co-27 is made ready to be checked.