



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/02/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------------------------------|----------------------------------|---------|
| 1 | OHP | CO 25 | OLR acted | reset | 18:30:00 | 18:40:00 | |
| 2 | OHP | CO 33M | OLR acted | reset | 15:30:00 | 15:35:00 | |
| 3 | OHP | BRC on CO 31 | LT not taking place, selector switch in local | put in remote 1450 | 14:50:00 | 15:00:00 | |
| 4 | OHP | WOBR on CO 29 | LT not working, control fuse blown | fuse replaced | 15:00:00 | 15:20:00 | |
| 5 | CHP | CC 125 | olr acted | reset | 20:20:00 | 20:30:00 | |
| 6 | CHP | CC 51 | MPD acted 5 times | reset | 15:00:00 | 15:05:00 | |
| 7 | IOSA | IOSA STREAM | communication problem stream unhealthy | NIU card power recycle done at LC and OM | 15:05:00 16:35:00 20:15:00 | 15:25:00 16:50:00 20:35:00 | 3 times |