



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/06/2025

Area: CHP

Equipment	Job
CC 220/221	Lighting ckt problem rectified
CC 35 ,S1	PPM was done
SCR 10	New OFC cable laid from operator cabin to MCC IO rack and connected .Communication restored