



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 18/12/2025

Area: OHP

Equipment	Job
brc-4 on co-8a	Ethernet cable is laid between mcc and operator cabin, and restored HMI communicaiton.
tbs-5	shifted form co-24 to co-22
tbs-1	shifted from co-22 to repair bay. rightboom motor termination and zss cable is removed, and sufficient lighting is provided for mechanical job.
co-67,rco-1a	motor and panel side ppm is done