



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/07/2025

Area: CHP

Equipment	Job
CC 54/132 gallery	Lighting restored after rectifying cable problems
SCR 10	HT coupler hot blowing and maintenance done
SCR 10	Shifted to CC 106 and started cable removal
SCR 4	HT transformer maintenance done and charged supply