



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/05/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	cc 132	brs acting /loose connection at module tb.	terminals tightend then ok	14:40:00	15:10:00	
2	CHP	s 1 on cc35	It not taking place pcrd cable tension acted	cable tension released.	16:20:00	16:35:00	