



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/12/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 28	LT not working,ACB tripped	made it on	02:30:00	02:50:00	
2	OHP	BRC on CO 32	LT not working,acb TRIPPED	MADE ITON	04:40:00	04:50:00	
3	OHP	CO 25	OLr acted	reset	04:55:00	05:00:00	
4	OHP	BRC on CO 31	ct not working,drive tripped	reset	23:15:00	23:30:00	2 times
5	OHP	BRC on Co 8A	bc not running,breaker tripped	made it on	23:00:00	23:15:00	
6	OHP	I/C 2 of 6.6 Kv	all yard machine in ohp and CHP feeding from i/c 2 tripped	i/c 2 made off and buscoupler made on in LBDS5 again normalized as per instruction of DNW	00:40:00	01:45:00	
7	OHP	Co 6a wobr	no power,	made it on crp panel,than found 240 V missing in machine,auxillary power contactor not pickup	03:20:00	06:30:00	pending
8	CHP	CC 51	MPD TRIPPED	made it on	03:25:00	03:30:00	
9	CHP	CC 103 on CC105	signal missing	position sensor bypassed	03:40:00	03:50:00	pending
10	CHP	cc 44	olr acted	reset	22:25:00	22:30:00	
11	CHP	CC 223	not healthy,remote mode qm2 trip	all interlock healthy but R1 relay not healthy missing frequently bypass relay	02:02:00	03:30:00	pending
12	CHP	CC 37 SCR 7	no power,1 no ht fuse blown	handover to A shift	05:30:00	06:00:00	