



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BF 1A	zss acted,probe disturbed	probe adjusted	20:10:00	20:20:00	
2	OHP	CO 20	BRS acted,fuse blown in I/O rack	fuse replaced	16:35:00	17:00:00	
3	OHP	co 32	BRS acted,belt piece found	reset	18:25:00	18:30:00	
4	CHP	CC 105 scr 10	LT not working,PCRD OT acted	Ot released	16:25:00	16:35:00	
5	CHP	CC 34 SCR1	LT not working,drive tripped	reset	16:55:00	17:10:00	
6	CHP	CC 203	motor trip	reset	17:45:00	17:55:00	
7	CHP	CC 31 scr 4	pcrd cable zigzag	properly rewinded	18:25:00	19:00:00	
8	CHP	CC 110	BRS acted,	sensor cleaned	18:10:00	18:20:00	