



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/12/2025

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 50	tripped on olr	reset done	07:32:00	07:45:00	
2	OHP	co 29	olr acted	reset done	13:00:00	13:10:00	
3	OHP	co 26	tripped on olr	reset done	10:35:00	10:45:00	
4	CHP	cc 58	tripped on olr due to over material.	reset done 2 times.	07:00:00	07:15:00	
5	CHP	cc 24	C/ S .acted due to jamming	reset done	09:50:00	10:00:00	
6	CHP	cc 58 .TT	TT LT NOT TAKING PLACE/pcrd cable R phase got short at old joint while doing LT due to material jamming and mpcb damaged	temporary joint done then given clearance	10:45:00	11:40:00	module replaced
7	CHP	scr 6 on cc38	tripped on olr.	reset done	06:30:00	06:45:00	
8	CHP	cc 35	tripped on olr.	reset done.	08:11:00	08:20:00	
9	CHP	cc 125	zss acting due more material on the conv.	clear the material in local .then ok	09:30:00	09:55:00	
10	CHP	scr 4 on cc31	pcrd cable looping on the ground/	pcrd cable winding done .then ok	10:40:00	11:15:00	
11	CHP	cc 51	mpd on olr due to feeding conver stopped	reset done 5 times	09:30:00	10:30:00	
12	CHP	cc 54	tripped on olr	reset done.	12:00:00	12:05:00	
13	CHP	cc 117	tripped on olr	reset done	11:20:00	11:25:00	
14	CHP	tis on cc130	magnet mpcb tripped 5 time s due high current.	reset done.	08:15:00	12:30:00	
15	CHP	cc130 tis	feed back kept bypass due to motor tipping	at i/o rack	12:35:00	12:40:00	