



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/07/2025

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 11 C/D	tripped on mpcb due to jamming	mpcb made on	09:30:00	09:45:00	
2	OHP	tt 4 on co 19	chute position signal not getting to ocr/mpcb tripped and not getting on	c/s bypassed at c/s relay then ok	09:30:00	09:45:00	
3	OHP	cc 27a	brs acting due to water	bypassed for operation requirement	07:50:00	08:00:00	brs kept in ckt at 12.15pm
4	OHP	co 3a	zss acting/material jamming at tailend	kept in local mode and again in plc	11:30:00	12:10:00	
5	OHP	co 11 C/D	TRIPPED ON MPCB DUE TO JAMMING	mpcb made on	10:45:00	10:45:00	
6	CHP	cc202	zss was in bypassed	zss module replaced and kept in ckt	09:30:00	09:50:00	
7	CHP	scr 5 on cc32	It not taking place/m 6 mpcb tripped	mpcb made on.then ok	06:40:00	06:50:00	
8	CHP	scr 5 on cc32	bc not running/chute and deck sheets jamming	inform to operation	07:15:00	08:15:00	c/s bypassed of bc
9	CHP	cc 223	control missing/c/s acted due to jamming	reset after cleaning	07:00:00	07:10:00	
10	CHP	scr 8 on cc112	It not taking place/pcrd cable fallen and mpced tripped	mpcb made on then cable winding done	10:05:00	10:15:00	
11	CHP	cc 202	zss acting/speed setting in zero	speed setting adjusted,	11:15:00	12:05:00	
12	CHP	scr 5 on cc32	It not taking place/m 6 mpcb tripped	mpcb made on then ok	13:00:00	13:10:00	
13	CHP	cc 26a	c/s acted	reset done	11:05:00	11:15:00	due material
14	CHP	cc 51	zss acted/belt snap	inform to operation	08:55:00	09:05:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/07/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	cp 9	forward /reverse not taking place/communication problem	plc power recycled done. this problem occurring frequently	06:45:00	07:30:00	pusher forward done in local mode up to inhaulzone then kept in remote