



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-29	Reported no operations taking place	MCB tripped in PLC panel.Made on	22:30:00	22:40:00	
2	OHP	WOBR on CO-29	Reported no operations taking place	Down limit acted.Boom lifted and tested okay	03:40:00	03:50:00	
3	OHP	WOBR on CO-29	Reported LT not taking place	PCRD tension acted.Released and tested okay	04:00:00	04:10:00	
4	OHP	CO-25	Reported tripped	OLR acted.Reset done	00:30:00	00:40:00	
5	CHP	CC-28	Reported tripped	OLR acted.Reset done(2 times)	23:15:00	02:15:00	
6	CHP	CC-29	Reported tripped	OLR acted.Reset done(2 times)	04:10:00	05:25:00	
7	CHP	CC-125	Reported tripped	OLR acted.Reset done	23:55:00	00:05:00	
8	CHP	CC-54	Reported tripped	OLR acted.Reset done(3 times)	00:15:00	05:30:00	
9	CHP	CC-51	MPD tripped	Reset done	05:00:00	05:10:00	
10	CHP	CC-131	Reported tripped	OLR acted.Reset done(3 times)	23:30:00	03:30:00	
11	CHP	CC-51A	ZSS acting	Cage stuck.Cage replaced and tested okay	00:10:00	00:40:00	