



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/05/2025

Area: IOSA

Equipment	Job
OC17A	RIGHT SIDE PULL CHORD,BELTSWAY SWITCH COVERED WITH TARPLIN SHEETS
OC23A	HEAD END HOIST PPM DONE
OC7A	HEAD END HOIST PPM DONE
OC7C	TAIL END HOIST PPM DONE
OC19A	TUNNEL SUMPUMPS AUTO MODE CHECKING DONE