



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/06/2025

Shift: A

Incharge(s): Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------|--|--|----------|----------|-------------------|
| 1 | OHP | CO-30 BRC | LT NOT WORKING | DRIVE TRIPPED IN OL ... RESET DONE | 08:00:00 | 08:20:00 | |
| 2 | OHP | CO-35 | OLR ACTED | RESET DONE | 11:35:00 | 11:40:00 | |
| 3 | OHP | CO-30 BRC | BC OLR ACTED | RESET DONE | 12:40:00 | 12:50:00 | |
| 4 | OHP | RSCO-10A | C/D AND B/D BOTH ARE IN TRIPPED CONDITION | RESET DONE AND TESTED | 11:10:00 | 11:30:00 | |
| 5 | OHP | CO-27A | OPR REQUEST TO KEEP BRS IN CKT | KEPT IN CKT | 09:00:00 | 09:10:00 | |
| 6 | OHP | CO-12 | ZSS BYPASS REQ FROM OPERATION | BYPASSED | 08:15:00 | 08:27:00 | AGAIN KEPT IN CKT |
| 7 | OHP | CO-66 | BRS BYPASS REQ FROM OPR | BYPASSED | 09:00:00 | 09:10:00 | KEPT IN CKT |
| 8 | OHP | CO-24 TBS | TRANSFORMER PROBLEM FROM C SHIFT | TRANSFORMER CHANGED BY G SHIFT ... TESTING GOING ON | 06:00:00 | 14:00:00 | |
| 9 | CHP | CC-33 SCR-4 | LUFF NOT WORKING | WRONG COMPLAINT (PUMP WAS NOT ON) | 06:35:00 | 06:45:00 | |
| 10 | CHP | CC-32 SCR-5 | SLEW NOT WORKING | WRONG COMPLAINT | 07:34:00 | 07:45:00 | |
| 11 | CHP | CC-126 | CHUT JAM CJD WAS IN BYPASS IN IO RACK | KEPT IN CKT ... CJD PROBLEM RECTIFIED | 09:10:00 | 09:45:00 | |
| 12 | CHP | CC-40 SCR-6 | ALL DRIVES STOPPED WORKING IN RUNNING | ACB OFF ... CONTROL WIRE LOOSE IN ACB PANEL ... FIXED PROPERLY AND ACB MADE ON | 12:50:00 | 13:10:00 | |



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/06/2025

Incharge(s): Lal Singh

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---|--------------------|----------------------|----------------------|---------|
| 13 | CHP | CC-131 | TRIPPED IN OLR | RESET DONE | 09:15:00 13:12:00 | 09:20:00 13:18:00 | |
| 14 | CHP | CC-54 | TRIPPED IN OLR | RESET DONE | 06:40:00 | 06:50:00 | |
| 15 | CHP | CC-53 | PULL CORD ACTED DUE TO MATERIAL AND CABLE DAMAGED | PULL CORD BYPASSED | 08:05:00 | 08:20:00 | |