



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 15	OLR ACTED	RESET	15:45:00 16:00:00 21:45:00	15:50:00 16:05:00 21:55:00	
2	OHP	BRC ON CO 28	EMERGENCY PB ACTED IN OPERATOR CABIN	RELEASED	15:50:00	16:05:00	
3	OHP	CO 33M LT	PCRD CABLE LOOP GIVEN	THEN OK	16:05:00	16:20:00	
4	OHP	BRC ON CO 33M	INTERLOCK CAGE GETTING STUCK	REPLACED THEN OK	16:40:00	17:00:00	
5	CHP	S1 ON CC 39	30 DEGREE LIMIT ACTED	RELEASED WITH MAGNET	15:50:00	16:00:00	
6	CHP	CC 39	OLR ACTED	RESET	19:00:00	19:05:00	
7	CHP	CC 32 R1	SLEW LIMIT ACTED	RELEASED	20:30:00	20:40:00	
8	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	17:30:00	17:35:00	
9	WT	OT3	D1 TRIPPED ON ENCODER FAULT	RESET	16:00:00	16:05:00	
10	WT	CO3	OLR ACTED	RESET	19:55:00	20:00:00	
11	IOSA	OC36A	ZSS CAGE STUCK WITH STONE	REMOVED THEN OK	17:30:00	17:45:00	