



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/06/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO29	tripped on olr	reset done	17:50:00 18:30:00	18:00:00 18:35:00	
2	OHP	TT4 chute position CO22	In TB cable loose connected	Connected	17:00:00	17:02:00	No delays
3	OHP	CO68	OLR acted	reset done	16:35:00	16:45:00	
4	OHP	CO61	BRS kept in ckt	As per operational request	21:00:00	21:01:00	
5	CHP	CO28	Chute jam acted found drive end side chute jamm	Informed to operation for clearanace after clearance reset done	16:50:00	17:05:00	
6	CHP	CC31	Tripped on drive fault over current	Reset done	16:15:00 19:10:00	16:20:00 19:15:00	
7	CHP	CC32	BRS bypassed as per operational request	Bypassed	16:10:00	16:15:00	
8	CHP	SCR5 on CC32	LT not working found MPCB trip 2 times	Reset done	16:40:00	16:55:00	
9	CHP	SCR6 on CC40	NO lights found control JB MCB trip	Reset done	18:30:00	18:40:00	